ANNUAL WATER QUALITY REPORT

Reporting Year 2022



Presented By City of Riviera Beach

MAYOR Ronnie L. Felder

USD BOARD MEMBERS Douglas A. Lawson, Chairperson Shirley D. Lanier, Chair Pro Tem Kashamba Miller-Anderson, Board Member Tradrick McCoy, Board Member Dr. Julia A. Botel, Board Member

<u>CITY MANAGER</u> Jonathan Evans, MPA, MBA, ICMA-CM

UTILITIES EXECUTIVE DIRECTOR Michael RT Low, CEng MIChemE



Our Mission Continues

We are once again pleased to present our annual water quality report covering all testing performed between January 1 and December 31, 2022. Over the years, we have dedicated ourselves to producing drinking water that meets all state and federal standards. We continually strive to adopt new methods for delivering the best-quality drinking water to you. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education while continuing to serve the needs of all our water users. Please remember that we are always available should you ever have any questions or concerns about your water.

Substances That Could Be in Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations, which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone



organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or http://water.epa.gov/drink/hotline.

Lead in Home Plumbing

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at (800) 426-4791 or at www. epa.gov/safewater/lead.

QUESTIONS?

For more information about this report, or for any questions relating to your drinking water, please call the Utility Special District Administration at (561) 845-4185.

Source Water Assessment

The Florida Department of Environmental Protection (FDEP) has performed a source water assessment on our system. These assessments were conducted to provide information about any potential sources of contamination in the vicinity of our wells. Potential sources of contamination identified include petroleum storage tanks and small- and large-quantity generators. The assessment was done in 2022, and there were 18 unique potential contaminant sources with low to moderate levels of susceptibility. This inventory only identifies potential sources of contamination. It does not mean that these sites are actively causing contamination of the drinking water source. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at https://prodapps.dep.state.fl.us/swapp/.

Where Does My Water Come From?

The Riviera Beach Utility Special District's water treatment plant obtains raw water from the East Coast surficial aquifers and pumps this water out of the ground through 27 wells located throughout the city.

Community Participation

We invite you to participate in our public forum and voice your concerns about your drinking water. Utility Special District Board meetings are held on the third Wednesday of each month, at 5:30 p.m., at Riviera Beach Marina Event Center, 190 East 13th Street, Riviera Beach.

FOG (Fats, Oils, and Grease)

You may not be aware of it, but every time you pour fat, oil, or grease (FOG) down your sink (e.g., bacon grease), you are contributing to a costly problem in the sewer collection system. FOG coats the inner walls of the plumbing in your house as well as the walls of underground piping throughout the community. Over time, these greasy materials build up and form blockages in pipes, which can lead to wastewater backing up into parks, yards, streets, and storm drains. These backups allow FOG to contaminate local waters, including drinking water. Exposure to untreated wastewater is a public health hazard. FOG discharged into septic systems and drain fields can also cause malfunctions, resulting in more frequent tank pump-outs and other expenses.

Communities spend billions of dollars every year to unplug or replace grease-blocked pipes, repair pump stations, and clean up costly and illegal wastewater spills. Here are some tips that you and your family can follow to help maintain a well-run system now and in the future:

NEVER:

Pour fats, oil, or grease down the house or storm drains.

Dispose of food scraps by flushing them.

Use the toilet as a wastebasket.

ALWAYS:

Scrape and collect fat, oil, and grease into a waste container, such as an empty coffee can, and dispose of it with your garbage.

Place food scraps in waste containers or garbage bags for disposal with solid wastes.

Place a wastebasket in each bathroom for solid wastes like disposable diapers, creams and lotions, and personal hygiene products, including nonbiodegradable wipes.

What's a Cross-Connection?

Cross-connections that contaminate drinking water distribution lines are a major concern. A cross-connection is formed at any point where a drinking water line connects to equipment (boilers), systems containing chemicals (air conditioning systems, fire sprinkler systems, irrigation systems), or water sources of questionable quality. Cross-connection contamination can occur when the pressure in the equipment or system is greater than the pressure inside the drinking water line (backpressure). Contamination can also occur when the pressure in the drinking water line drops due to fairly routine occurrences (main breaks, heavy water demand), causing contaminants to be sucked out from the equipment and into the drinking water line (backsiphonage).

Outside water taps and garden hoses tend to be the most common sources of cross-connection contamination at home. The garden hose creates a hazard when submerged in a swimming pool or attached to a chemical sprayer for weed killing. Garden hoses that are left lying on the ground may be contaminated by fertilizers, cesspools, or garden chemicals. Improperly installed valves in your toilet could also be a source of cross-connection contamination.

Community water supplies are continuously jeopardized by cross-connections unless appropriate valves, known as backflow prevention devices, are installed and maintained. We have surveyed industrial, commercial, and institutional facilities in the service area to make sure that potential cross-connections are identified and eliminated or protected by a backflow preventer. We also inspect and test backflow preventers to make sure that they provide maximum protection. For more information on backflow prevention, contact the Safe Drinking Water Hotline at (800) 426-4791.

Tap versus Bottled

Thanks in part to aggressive marketing, the bottled water industry has successfully convinced us all that water purchased in bottles is a healthier alternative to tap water. However, according to a four-year study conducted by the Natural Resources Defense Council (NRDC), bottled water is not necessarily cleaner or safer than most tap water. In fact, about 40 percent of bottled water is actually just tap water, according to government estimates.

The Food and Drug Administration (FDA) is responsible for regulating bottled water, but these rules allow for less rigorous testing and purity standards than those required by the U.S. EPA for community tap water. For instance, the high mineral content of some bottled waters makes them unsuitable for babies and young children. Further, the FDA completely exempts bottled water that's packaged and sold within the same state, which accounts for about 70 percent of all bottled water sold in the United States.

People spend 10,000 times more per gallon for bottled water than they typically do for tap water. If you get your recommended eight glasses a day from bottled water, you could spend up to \$1,400 annually. The same amount of tap water would cost about 49 cents. Even if you installed a filter device on your tap, your annual expenditure would be far less than what you'd pay for bottled water. For a detailed discussion on the NRDC study results, check out its website at https://goo.gl/Jxb6xG.

Water Conservation Tips

You can play a role in conserving water and save yourself money in the process by becoming conscious of the amount of water your household is using and looking for ways to use less whenever you can. It is not hard to conserve water. Here are a few tips:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank. Watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from an invisible toilet leak. Fix it and you can save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water-using appliances. Then check the meter after 15 minutes. If it moved, you have a leak.

What Are PFAS?

Per- and polyfluoroalkyl substances (PFAS) are a group of manufactured chemicals used worldwide since the 1950s to make fluoropolymer coatings and products that resist heat, oil, stains, grease, and water. During produc-



tion and use, PFAS can migrate into the soil, water, and air. Most PFAS do not break down; they remain in the environment, ultimately finding their way into drinking water. Because of their widespread use and their persistence in the environment, PFAS are found all over the world at low levels. Some PFAS can build up in people and animals with repeated exposure over time.

The most commonly studied PFAS are perfluorooctanoic acid (PFOA) and perfluorooctane sulfonic acid (PFOS). PFOA and PFOS have been phased out of production and use in the United States, but other countries may still manufacture and use them.

Some products that may contain PFAS include:

- Some grease-resistant paper, fast food containers/wrappers, microwave popcorn bags, pizza boxes
- Nonstick cookware
- Stain-resistant coatings used on carpets, upholstery, and other fabrics
- Water-resistant clothing
- Personal care products (shampoo, dental floss) and cosmetics (nail polish, eye makeup)
- Cleaning products
- Paints, varnishes, and sealants

Even though recent efforts to remove PFAS have reduced the likelihood of exposure, some products may still contain them. If you have questions or concerns about products you use in your home, contact the Consumer Product Safety Commission at (800) 638-2772. For a more detailed discussion on PFAS, please visit http://bit.ly/3Z5AMm8.

How Do We Treat Our Water?

Currently, the Riviera Beach Utility Special District operates a lime-softening treatment plant. Raw water from the wellfield is first air-stripped to eliminate volatile organic compounds. The water is then treated with chemicals (lime and polymer) and disinfected with a combination of chlorine and ammonia. This occurs in a treatment unit that both softens and clarifies the water. The water is then filtered to remove turbidity and pumped to our consumers throughout our distribution system. Ensuring that a disinfection residual remains in our water pipes throughout the distribution system is an important outcome of treatment.

What's Your Water Footprint?

You may have some understanding about your carbon footprint, but how much do you know about your water footprint? The water footprint of an individual, community, or business is defined as the total volume of freshwater that is used to produce the goods and services that are consumed by the individual or community or produced by the business. For example, 11 gallons of water is needed to irrigate and wash the fruit in one half-gallon container of orange juice. Thirty-seven gallons of water is used to grow, produce, package, and ship the beans in that morning cup of coffee. Two hundred and sixty-four gallons of water is required to produce one quart of milk, and 4,200 gallons of water is required to produce two pounds of beef.

According to the U.S. EPA, the average American uses over 180 gallons of water daily. In fact, in the developed world, one flush of a toilet uses as much water as the average person in the developing world allocates for an entire day's cooking, washing, cleaning, and drinking. The annual American per capita water footprint is about 8,000 cubic feet, twice the global per capita average. With water use increasing sixfold in the past century, our demands for freshwater are rapidly outstripping what the planet can replenish. To check out your own water footprint, go to www.watercalculator.org.

Water Main Flushing

Distribution mains (pipes) convey water to homes, businesses, and hydrants in your neighborhood. The water entering distribution mains is of very high quality; however, water quality can deteriorate in areas of the distribution mains over time. Water main flushing is the process of cleaning the interior of water distribution mains by sending a rapid flow of water through the mains.

Flushing maintains water quality in several ways. For example, flushing removes sediments like iron and manganese. Although iron and manganese do not pose health concerns, they can affect the taste, clarity, and color of the water. Additionally, sediments can shield microorganisms from the disinfecting power of chlorine, contributing to the growth of microorganisms within distribution mains. Flushing helps remove stale water and ensures the presence of fresh water with sufficient dissolved oxygen and disinfectant levels and an acceptable taste and smell.

During flushing operations in your neighborhood, some short-term deterioration of water quality, though uncommon, is possible. You should avoid tap water for household uses at that time. If you do use the tap, allow your cold water to run for a few minutes at full velocity before use, and avoid using hot water to prevent sediment accumulation in your hot water tank. Please contact us if you have any questions or if you would like more information on our water main flushing schedule.

Think before You Flush!

Flushing unused or expired medicines can be harmful to your drinking water. Properly disposing of unused or expired medication helps protect you and the environment. Keep medications out of our waterways by disposing responsibly. To find a convenient drop-off location near you, please visit https://bit.ly/3IeRyXy.



Test Results

Our water is monitored for many different kinds of substances on a very strict sampling schedule, and the water we deliver must meet specific health standards. Here, we only show those substances that were detected in our water (a complete list of all our analytical results is available upon request). Remember that detecting a substance does not mean the water is unsafe to drink; our goal is to keep all detects below their respective maximum allowed levels.

The state recommends monitoring for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

PRIMARY REGULATED CONTAMINANTS											
Microbiological Contaminants											
CONTAMINANT AND UNIT OF MEASUREMENT	TT VIOLATION (YES/NO)	DATES OF SAMPLING (MO./YR.)		RESULT	MCLG 1	FT LIM	ELY SO	URCE (CONTAMINATION		
Total Coliform Bacteria (positive samples)	No	Monthly 2022		Positive ¹	NA 7	ГТ N	aturally	turally present in the environment			
Inorganic Contaminants											
CONTAMINANT AND UNIT OF MEASUREMENT	DATES OF SAMPLING MCL VIOLATION LEVEL (MO./YR.) (YES/NO) DETECTE		LEVEL DETECTED	RANGE OF RESULTS	F MCLG MCL LIKELY S			SOUR	OURCE OF CONTAMINATION		
Nitrate [as nitrogen] (ppm)	06/01/2022	No	0.95	0.95-0.95	10	10	Runof	noff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits			
Nitrite [as nitrogen] (ppm)	06/01/2022	No	0.18	0.18-0.18	1	1	Runof	noff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits			
Synthetic Organic Contaminants, Including Pesticides and Herbicides											
Dalapon (ppb)	06/10/2022 No		ND	NA	200	200	Runof	f from herbicide used on rights-of-way			
STAGE 1 DISINFECTANTS AND DISINFECTION BY-PRODUCTS											
CONTAMINANT AND UNIT OF MEASUREMENT	DATES OF S (MO./)	AMPLING MCL (R.) (1	VIOLATION YES/NO)	LEVEL DETECTED	RANGE RESUL	OF TS	MCLG ([MRDL	OR G]	ICL OR MRDL] LIKELY SOURCE OF CONTAMINATION		
Chloramines (ppm)	Monthly	2022	No	3.15	0.6–4	<i>i</i> .0	[4]		[4.0] Water additive used to control microbes		
STAGE 2 DISINFECTANTS AND DISINFECTION BY-PRODUCTS											
CONTAMINANT AND UNIT OF MEASUREMENT	DATES OF S (MO./'	AMPLING MCL V YR.) (YE	/IOLATION ES/NO)	LEVEL DETECTED	RANGE RESUL	OF .TS	MCLG	мс	LIKELY SOURCE OF CONTAMINATION		
Haloacetic Acids (five) [HAA5]-Stage 2 (p	opb) Quarterl	y 2022	No	21.88	9.6–2	5.6	NA	6	By-product of drinking water disinfection		
TTHM [total trihalomethanes]-Stage 2 (p	opb) Quarterl	y 2022	No	24.43	8.5–2	6.4	NA	8	By-product of drinking water disinfection		
Lead and Copper (Tap water samples were collected from sites throughout the community)											
CONTAMINANT AND UNIT OF MEASUREMENT	DATES OF SAMPLING (MO./YR.)	AL EXCEEDANCE (YES/NO)	90TH PERCENTIL RESULT	NO. OF S E SITES EX TH	Sampling (Ceeding E al	MCLO	م (AC) G LE	AL TION /EL)	KELY SOURCE OF CONTAMINATION		
Copper [tap water] (ppm)	10/27/2020	No 0.213			0		1	.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives		
Lead [tap water] (ppb)	10/27/2020	No 0.00217		0		0	0 15		Corrosion of household plumbing systems; erosion of natural deposits		

¹The Utility Special District collected a total of 510 samples in 2022, with only 2 positive for total coliform. With proper flushing and resampling, the situation was corrected within 24 hours.



Definitions

90th %ile: The levels reported for lead and copper represent the 90th percentile of the total number of sites tested. The 90th percentile is equal to or greater than 90% of our lead and copper detections.

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable.

0

ND (Not detected): Indicates that the substance was not found by laboratory analysis.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

What type of container is best for storing water?

Consumer Reports has consistently advised that glass or BPA-free plastics such as polyethylene are the safest choices. To be on the safe side, do not use any container with markings on the recycle symbol showing 7PC (that's code for BPA). You could also consider using stainless steel or aluminum with BPA-free liners.

How much emergency water should I keep?

Typically, one gallon per person per day is recommended. For a family of four, that would be 12 gallons for three days. Humans can survive without food for one month but can only survive one week without water.

How long can I store drinking water?

The disinfectant in drinking water will eventually dissipate, even in a closed container. If that container housed bacteria prior to filling up with the tap water, the bacteria may continue to grow once the disinfectant has dissipated. Some experts believe that water can be stored up to six months before needing to be replaced. Refrigeration will help slow the bacterial growth.

How long does it take a water supplier to produce one glass of treated drinking water?

It can take up to 45 minutes to produce a single glass of drinking water.

How many community water systems are there in the U.S.?

About 53,000 public water systems across the United States process 34 billion gallons of water per day for home and commercial use. Eighty-five percent of the population is served by these systems.

Which household activity wastes the most water?

Most people would say the majority of water use comes from showering or washing dishes; however, toilet flushing is by far the largest single use of water in a home (accounting for 40 percent of total water use). Toilets use about 4 to 6 gallons per flush, so consider an ultra-low-flow (ULF) toilet, which requires only 1.5 gallons.